

BUILDING A WORLD OF DIFFERENCE®



High Reliability Power System Design

Buenos Aires, Argentina June 25 & 26, 2009

Keene M. Matsuda, P.E.

Regional Electrical Manager Senior Member IEEE IEEE/PES Distinguished Lecturer ke.matsuda@ieee.org

Motors

Component	Energy Loss, FL (%)
Motors: 1 to 10 Hp	14.00 to 35.00
Motors: 10 to 200 Hp	6.00 to 12.00
Motors: 200 to 1500 Hp	4.00 to 7.00
Motors: 1500 Hp and u	p 2.30 to 4.50
Variable Speed Drives	6.00 to 15.00
Motor Control Centers	0.01 to 0.40
MV Starters	0.02 to 0.15
MV Switchgear	0.005 to 0.02
LV Switchgear	0.13 to 0.34

Reference: ANSI/IEEE Standard 141 (Red Book), Table 55

Motors

- Motor driven systems represent about 60% of all electrical energy used
- Energy Policy Act of 1992 set min efficiencies for motors in the U.S.
- Manufacturers have increased motor efficiencies in the interim
- Premium-efficiency motors can therefore decrease losses

Reference: Copper Development Association

Variable Frequency Drives

- Very common device for energy efficiency
- AC to DC to Variable output with V/Hz constant
- Not suitable in all cases
- Optimum: Must have varying load
- Or dictated by application
- Example: Chemical feed pumps, small Hp, but precise dosing

Variable Frequency Drives



Reference: Energy Savings in Industry, Chapter 5, UNEP-IETC



- VFDs convert 480 V at 60 Hz to a variable voltage with variable frequency
- VFD holds constant the ratio of V/Hz
- Nominal is 480 V/60 Hz = 8.0 at 100% motor speed
- If you want 50% speed, reduce the voltage to 240 V
- But need to correspondingly reduce the frequency by 50% or else motor won't operate
- Thus frequency is 30 Hz at 240 V, or 240 V/30 Hz = 8.0 constant



- Same for any speed in the operating range
- If you want 37% speed:
- 480 V x 0.37 = 177.6 V
- If V/Hz is held constant at 8.0,
- Then frequency is V/8.0 = 177.6 V/8.0 = 22.2 Hz

- The VFD works similar to a UPS where incoming AC in rectified to DC, then inverted back to AC
- Because of the nearly infinite range of frequencies possible, the associated carrier frequencies of the VFD output circuit can generate abnormal EMF
- This EMF can corrupt adjacent circuit cables
- One method is to provide shielding around the cables between the VFD and the motor

- This shielding can easily be a steel conduit
- This works if the conduit is dedicated between the VFD and the motor
- If part of the cable run is in underground ductbank, then the PVC conduit in the ductbank no longer provides that shielding

- Possible to install a steel conduit thru the ductbank to counteract
- But that would then restrict flexibility in the future to move these VFD cables to a spare conduit which would then be PVC
- Too costly to install all ductbank with RGS conduit

- Also, if the cables pass thru a manhole or pull box along the way, it is very difficult to keep the VFD cables sufficiently separated from the other normal circuits
- If EMF is a problem with adjacent circuits, easy solution is to select 600 V, 3-conductor, shielded cables

- However, the true nature of the EMF problem from VFD cables is not well known or calculated
- Much depends on the type of VFD installed, 6-pulse, 12-pulse, 18-pulse
- If there is an reactor on the output of the VFD
- How well the reactor mitigates harmonics
- What the length of the cable run is, i.e., introducing impedance in the circuit from the cable

- More significantly, the actual current flowing thru the cable can impact the EMF
- And, exactly what the voltage and frequency is at any one time since the voltage and frequency will vary
- In the end, right now, until more is known, prudent engineering is to specify shielded cables for VFDs with motors 60-100 Hp and above



California Title 24

- California's mandate for energy efficiency
- Three major elements: architectural design, HVAC, lighting
- Lighting: limiting watts/sq ft by room classification, motion sensors, etc.
- Title 24 revised Oct 2005 to close loopholes
- Prior: lighting indoors in air conditioned spaces
- Now: all lighting indoors and now outdoors

Lighting Design

- HID lighting: HPS, LPS, MH, MV
- More efficient than incandescent or fluorescent
- Fluorescent provides better uniformity
- LPS is most efficient; poor in visual acuity
- And now LED in increasing applications

Lighting Design

- Outdoor lighting on poles more complicated
- Factors: Pole height Pole spacing Fixtures per pole Fixture lamps type Fixture wattage Fixture light distribution pattern
- Photometric analysis using software (Visual, AGI32, etc.)
- Calculate average fc illumination & uniformity
- Life safety illumination for egress: 1 fc average, 0.1 fc one point



Photometric Calculations – Lighting DeSoto® M50

Emergency Lighting



DM5C18SHS92



BUILDING A WORLD OF DIFFERENCE®



Photometric Calculations – Lighting



Photometric Calculations – Lighting

*0.0 *0.0 *0.1 *0.1 *0.1 *0.2 *0.2 *0.3 *0.2 *0.3 *0.1 *0.1 *0.1 *0.1 *0.1 *0.1 *0.3 *0.2 *0.2 *0.3 *0.2 *0.1 *0.1 *0.1 *0.0 *0.0 *0.0 *0.0 ^{*}0.0 ^{*}0.0 ^{*}0.1 ^{*}0.1 ^{*}0.2 ^{*}0.3 <u>*0.4 ^{*}0.4 ^{*}0.3 *0.4 *0.3 *0.4 *0.2 *0.1 *0.1 *0.1 *0.1 *0.2 *0.4 *0.3 *0.4 *0.3 *0.4 *0.3 *0.2 *0.1 *0.1 *0.0 *0.0 *0.0</u> 10 101 10.1 10.3 10.5 10.7 10.7 10.7 10.5 0.4 10.4 10.2 101 10.1 10.1 10.2 10.4 10.2 10.4 10.5 10.7 10.7 10.7 10.7 10.3 10.1 10.1 10.0 10.0 10.0 °0.0 (*0.1 / 0.1 *0.2 *0.4 *0.7 *0.9 *0.9 *0.7 *0.8 *0.7 *0.8 *0.4 *0.2 *0.1 *0.1 *0.1 *0.2 *0.4 *0.8 *0.7 *0.4 *0.9 *0.7 *0.4 *0.2 ^{0.1}1 *0.1 *0.0 *0.0 0.0 🕼 tolf toll tols 😕 tol7 🌆 til7 til3 🏹 o tol8/tol4 tol2 toll toll toll toll tol2 🔩 tol8 71.0 til3 til7 71.0 tol7 Yol5 tol3 tol% tol1 Yol0 tol0 0.1 °0/1 °0.2 °0.3 °0.5 °0.7 🖧 °1.8 °1.4 °y/2 °0.5 °0.2 °0.2 °0.2 °0.1 °0.1 °0.2 °0.2 °0.2 °0.2 °0.2 °1.4 °1.8/°0.8 °0.7 %0.5 °0.3 °0.2 °0.1 °0.1 °0.0 0.1 0.1 °0.0 ¹0.0 ¹0.0 ¹0.1 ¹0.1 ¹0.1 ¹0.1 ¹0.1 ¹0.1 ¹0.1 ¹0.2 ¹0.2 ¹0.2 ¹0.3 ¹0.3 ¹0.3 ¹0.3 ¹0.2 ¹0.2 ¹0.2 ¹0.1 ¹

BUILDING A WORLD OF DIFFERENCE®







Photometric Calculations – Lighting





Photometric Calculations – Roadway Lighting

Visual Roadway Lighting Tool - GE 150 W HPS at 25 OC

Illuminance



Grid Statistics

Average	4.9	fc
Max	6.2	fc
Min	3.5	fc
Max/Min	1.8	
Avg/Min	1.4	

Grid Properties

Number of Rows	10	
Row Spacing	2.5	ft
Number of Columns	4	
Column Spacing	6	ft



- K-Factor is a measure of the amount of harmonics in a power system
- K-Factor can be used to specify a dry-type transformer such that it can handle certain levels of harmonic content
- K-Factor rated transformers are generally built to better dissipate the additional heat generated from harmonic current and voltage

- Harmonic content is small cycle waveforms along the sine wave that distort the original sine wave
- The slightly higher RMS voltage and current on the sine waves is useless since it raises the voltage and current







- To calculate K-Factor, must have a power systems analysis software program like ETAP or SKM, etc.
- Model all harmonic-producing equipment: biggest culprit is the 6-pulse VFD
- Formula for calculating K-Factor:

K-Factor =
$$\sum h p.u^2 x h^2$$

- Where, Ih p.u. = Current harmonic in per unit
- Where, h = Odd harmonic (3, 5, 7, 9, 11, 13, etc.)

		BRANCH TAN	BULATION		
Project: Mot	torola High Voltage Upgrade	e ===========		Page:	38
Location: Pla	antation, Florida	PowerStatic	on 3.0.1C	Date:	08-08-2000
Contract: 258	865A-1			SN:	PBPOWERINC
Engineer: PB	Power Inc.	Study Case:	Normal	File:	Motorolal

Branch						% Ha	rmonic	Curre	nt Con	tents	in 1 M	VA Bas	e				
ID	2 25	3 29	4 31	5 35	6 37	7 41	8 43	9 47	10 49	11 53	12 55	13 59	14 61	15 65	17 67	19 71	23 73
PT-1	0.00	0.00	0.00	0.00 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
T-1(SUB-1)	0.00 2.54	0.00 2.08	0.00 1.92	16.34 1.62	0.00 1.53	11.24 1.32	$0.00 \\ 1.24$	$0.00 \\ 1.10$	0.00 1.03	6.56 0.00	0.00	5.47 0.00	0.00 0.00	0.00 0.00	4.05 0.00	3.57 0.00	2.79 0.00
T-2(SUB-2)	$0.00 \\ 0.48$	$0.00 \\ 0.40$	0.00 0.37	6.52 0.31	0.00 0.29	3.79 0.24	0.00 0.23	0.00 0.19	0.00 0.18	1.15 0.00	0.00	0.97 0.00	0.00 0.00	0.00 0.00	0.74 0.00	0.66 0.00	0.53 0.00
T-3(SUB-3)	0.00 3.98	0.00 3.36	0.00 3.15	$\substack{21.14\\2.74}$	0.00 2.63	14.88 2.31	0.00 2.21	0.00 1.99	0.00 1.89	9.14 0.00	0.00	7.73 0.00	0.00 0.00	0.00 0.00	5.91 0.00	5.30 0.00	4.28 0.00
T-4(SUB-4)	0.00 0.69	0.00 0.57	0.00 0.52	9.41 0.44	$0.00 \\ 0.41$	5.34 0.34	0.00 0.31	0.00 0.26	$0.00 \\ 0.24$	1.53 0.00	0.00	1.32 0.00	0.00 0.00	0.00 0.00	1.03 0.00	0.93 0.00	0.75 0.00
T-5(SUB-5)	0.00 0.00	0.00 0.00	0.00 0.00	$4.46 \\ 0.00$	0.00 0.00	2.19 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.13 0.00	0.00	0.12 0.00	0.00 0.00	0.00 0.00	$0.10 \\ 0.00$	0.00 0.00	0.00 0.00
T-6(SUB 6)	0.00 2.30	0.00 1.92	0.00 1.79	20.47 1.53	$0.00 \\ 1.46$	12.80 1.26	0.00 1.19	0.00 1.05	0.00 0.98	$5.44 \\ 0.00$	0.00	4.58 0.00	0.00 0.00	0.00 0.00	3.48 0.00	3.11 0.00	2.50 0.00
T-7(SUB-7)	0.00 1.87	$0.00 \\ 1.48$	$0.00 \\ 1.34$	16.37 1.10	0.00 1.03	10.66 0.86	0.00 0.80	0.00 0.69	0.00 0.63	$5.48 \\ 0.00$	0.00	4.49 0.00	0.00 0.00	0.00 0.00	3.20 0.00	2.77 0.00	2.08 0.00
T-8(SUB-8)	0.00 1.22	0.00 0.99	0.00 0.90	18.20 0.73	0.00 0.67	10.33 0.54	0.00 0.49	0.00 0.39	0.00 0.34	2.86 0.00	0.00	2.44 0.00	0.00 0.00	0.00 0.00	1.88 0.00	1.68 0.00	1.33 0.00



Nominal kVA I	Ratina:		3000			
Fundamental	Primary Curre	nt: *	66.0			
Harmonic	%I _{ћъц} *	I _{hpu.}	(Ihpu) ²	h²	$(\mathbf{I}_{\mathbf{h}\mathbf{p}\mathbf{u}})^2 \cdot \mathbf{h}^2$	
3	0.00	0.00000	0.00000	9	0.00000	
5	6.90	0.06900	0.00476	25	0.11903	
7	3.92	0.03920	0.00154	49	0.07530	
9	0.00	0.00000	0.00000	81	0.00000	
11	1.09	0.01090	0.00012	121	0.01438	
13	0.92	0.00920	0.00008	169	0.01430	
15	0.00	0.00000	0.00000	225	0.00000	
17	0.71	0.00710	0.00005	289	0.01457	
19	0.64	0.00640	0.00004	361	0.01479	
21	0.00	0.00000	0.00000	441	0.00000	
23	0.50	0.00500	0.00003	529	0.01323	
25	0.46	0.00460	0.00002	625	0.01323	
27	0.00	0.00000	0.00000	729	0.00000	
29	0.37	0.00370	0.00001	841	0.01151	
31	0.34	0.00340	0.00001	961	0.01111	
33	0.00	0.00000	0.00000	1089	0.00000	
35	0.28	0.00280	0.00001	1225	0.00960	
37	0.25	0.00250	0.00001	1369	0.00856	
39	0.00	0.00000	0.00000	1521	0.00000	
41	0.20	0.00200	0.00000	1681	0.00672	
43	0.18	0.00180	0.00000	1849	0.00599	
45	0.00	0.00000	0.00000	2025	0.00000	
47	0.15	0.00150	0.00000	2209	0.00497	
49	0.13	0.00130	0.00000	2401	0.00406	
			L L	Eactor =	0.34	







System Design Summary

- A. Prepare Load Study Calculation
- B. Size Transformer to 480 V Loads
- C. Size 480 V Motor Control Center (MCC)
- D. Select Short Circuit Rating of 480 V MCC
- E. Size 480 V Feeder from Transformer to MCC
- F. Size Transformer 12 kV Primary Disconnect
- G. Select Surge Protection at Transformer Primary
- H. Size 12 kV Feeder to Transformer (MV Cable)


- A. <u>Prepare Load Study Calculation</u>
- Must have list of loads for facility
- Is facility load 500 kW, or 5,000 kW?
- Cannot size anything without loads
- Detailed information is best approach
- Line item for each major load, i.e., pump, fan, etc.
- Can lump smaller receptacle loads together for now



- Pumps
- Fans
- Compressors
- Valves
- 480 V transformer to 120 V auxiliary loads
- Lighting
- Etc.



BLUE HIGHLIGHTED AREA FOR INPUT DATA	1	1										
EQUIPMENT	LOAD			DEM		CONNECT	ED			RUNNING	ì	
NAME	TYPE	LOAD	PF	FACT	KY-C	KYAR-C	KVA-C	AMPS-C	KY-B	KYAB-B	KYA-R	AMPS
Treated water Pump 1 to Main East Zone	AFD	350.00	0.95	1.00	326.68	107,4	343.3	431.59	326.7	107.4	343.9	431.59
Treated Water Pump 2 to Main East Zone	AFD	350.00	0.95	1.00	326.68	107.4	343.9	431.59	326.7	107.4	343.9	431.59
Treated Water Pump 1 to Main West Zone	AFD	200.00	0.95	0.00	186.65	61.3	196.5	246.60	0.0	0.0	0.0	0.00
Treated Water Pump 2 to Main West Zone	AFD	200.00	0.95	0.00	186.65	61.3	196.5	246.60	0.0	0.0	0.0	0.00
Thunderbird well Pump No. 10	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186,60
Thunderbird well Pump No. 13 OT 4	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.61
Thunderbird well Pump No. 17	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
Nunderbird well Pump No. 23	AFD	150,00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
Nacimento Turnout Feed	KVA	25.0	0.80	DT 4 0.80	20.00	15.0	25.0	31.38	16.0	12.0	20.0	25.10
TWP disc valves (0.5HP each, West)	MOTOR	1.00	0.72	0.00	0.92	0.9	1.3	<u>3 af</u>	4 0.0	0.0	0.0	0.00
TWP disc. valves (0.5HP each, East)	MOTOR	1.00	0.72	0.0	0.92	0.9	1.3	2.10	0.0	0.0	0.0	0.00
LT-TVPS	KVA	30.00	0.80	0,0	21.00	18.0	30.0	37.65	16.8	12.6	21.0	26.36
Overflow Basin Pump 1	MOTOR	5.00	0.82	.00	4.24	3.0	5.2	7.60	4.2	3.0	5.2	7.60
Overflow Basin Pump 2	MOTOR	5.00	0.82	0.00	4.24	3.0	5.2	7.60	0.0	0.0	0.0	0.00
Backwash Recovery Pump 1	AFD	5.00	0.95	1.00	5.90	1.9	6.2	7.80	5.9	1.9	6.2	7.80
Backwash Recovery Pump 2	AFD	5.00	0.95	0.00	5.90	1.9	6.2	7.80	0.0	0.0	0.0	0.00
MPC-1	KVA	5.00	0.80	0.80	4.00	3.0	5.0	6.28	3.2	2.4	4.0	5.02
MPC-2	KVA	5.00	0.80	0.80	4.00	3.0	5.0	6.28	3.2	2.4	4.0	5.02
MPC-4	KVA –	5.00	0.80	0.80	4.00	3.0	5.0	6.28	3.2	2.4	4.0	5.02
VBF-1001	MOTOR	0.50	0.60	1.00	0.48	0.6	0.8	1.10	0.5	0.6	0.8	1.10
Existing Feed PVE-6110	KVA –	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
Existing Feed PVE-6113	KVA	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
Existing Feed PVE-6117	KVA	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
Existing Feed PVE-6123	KVA –	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
Pachaged Heat Pump PHP-101	KVA –	28.00	0.80	1.00	22.40	16.8	28.0	35.14	22.4	16.8	28.0	35.14
Site Lighting (3)	KVA –	10.00	0.80	1.00	8.00	6.0	10.0	12.55	8.0	6.0	10.0	12.55
Site Lighting (1)	KVA –	3.00	0.80	1.00	2.40	1.8	3.0	3.77	2.4	1.8	3.0	3.77
<u>Membrane Power Panel (PP-MEME)</u>	KVA		0.92	1.00	244.40	101.51	264.64	332.15	185.7	76.6	200.8	252.07
Nembrane Power Panel (PP-CHENI)	KVA		0.99	1.00	138.18	24.25	140.29	176.08	135.0	21.6	136.8	171.66
				0.00		0.0	0.0	0.00	0.0	0.0	0.0	0.00
TOTAL BUS LOADS	f 4				2181.6	799.7	2323.5		1711.2	625.4	1821.9	
7 0											ER.	
CONNECTED FLA		2916.3)	P.F	0.939							
RUNNING FLA		2286.7		P.F.	0.939							
									B	LACK	& VE	ATCH
								T	_			

- View 1 of 4:
- Each load and type is entered in the spreadsheet
- Load types can be AFD = adjustable frequency drive, or motor, or kVA

ELLE HIGHLIGHTED AREA FOR INPUT DATA		
EQUIPMENT	LOAD	
NAME	TYPE	LOAD
Treated Water Pump 1 to Main East Zone	AFD	350.00
Treated Water Pump 2 to Main East Zone	AFD	350.00
Treated Water Pump 1 to Main West Zone	AFD	200.00
Treated Water Pump 2 to Main West Zone	AFD	200.00
Thunderbird well Pump No. 10	AFD	150.00
Thunderbird well Pump No. 13	AFD	150.00
Thunderbird well Pump No. 17	AFD	150.00
Thunderbird well Pump No. 23	AFD	150.00
Nacimento Turnout Feed	KVA	25.0
TWP disc. valves (0.5HP each, West)	MOTOR	1.00
TWP disc. valves (0.5HP each, East)	MOTOR	1.00
LT-TWPS	KVA	30.00
Overflow Basin Pump 1	MOTOR	5.00

- View 2 of 4:
- PF and demand factor is entered for each load
- Power factor = from standard motor design tables, unless actual is known
- Demand Factor = Ratio of actual demand to nameplate rating, or 0.00 if standby load or off
- Example: Pump demand = 8.1 Hp, from 10 Hp rated motor, DF = 8.1 Hp/10 Hp = 0.81
- Example: Small transformer demand = 3.4 kVA, from 5 kVA rated transformer, DF = 3.4 kVA/5 kVA = 0.68



	I			
<u>ELLE HIGHLIGHTED AREA FOR INPUT DATA</u>				
EQUIPMENT	LOAD			DEM
NAME	TYPE	LOAD	PF	FACT
Treated Water Pump 1 to Main East Zone	AFD	350.00	0.95	1.00
Treated Water Pump 2 to Main East Zone	AFD	350.00	0.95	1.00
Treated Water Pump 1 to Main West Zone	AFD	200.00	0.95	Off 0.00
Treated Water Pump 2 to Main West Zone	AFD	200.00	0.95	0.00
Thunderbird well Pump No. 10	AFD	150.00	0.95	1.00
Thunderbird well Pump No. 13	AFD	150.00	0.95	On 1.00
Thunderbird well Pump No. 17	AFD	150.00	0.95	1.00
Thunderbird well Pump No. 23	AFD	150.00	0.95	1.00
Nacimento Turnout Feed	KVA	25.0	0.80	0.80
TWP disc. valves (0.5HP each, West)	MOTOR	1.00	0.72	0.00
TWP disc. valves (0.5HP each, East)	MOTOR	1.00	0.72	0.00
LT-TWPS	KVA	30.00	0.80	0.70
Overflow Basin Pump 1	MOTOR	5.00	0.82	1.00

- View 3 of 4:
- Connected values represent any load "connected" to the power system regardless of operation or not
- Running values represent "actual operating" loads at max demand
- If a pump is a standby, or backup, or spare, this pump would be turned off, or shown as zero, in the running columns
- The Demand Factor entry of zero is what turns off any particular load

- View 3 of 4:
- All connected values are calculated from input of load Hp, kVA, and power factor with formulas below:
- 1 Hp = 0.746 kW
- kVA = kW/PF



-1-1										
	DEM			CONNECTE	ED			RUNNING	i	
	FACT		KY-C	KYAR-C	KYA-C	AMPS-C	K¥-R	KYAR-R	KYA-R	AMPS
1		1.00	326.68	107.4	343.9	431.59	326.7	107.4	343.9	431.59
i	_	1.00	326.68	107.4	343.9	431.59	326.7	107.4	343.9	431.59
i	Off	0.00	186.65	61.3	196.5	246.60	0.0	0.0	0.0	0.00
i		0.00	186.65	61.3	196.5	246.60	0.0	0.0		0.00
i		1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
i		100	141.24	46.4	148 7	186 60	141.2	46.4	148 7	186 60
i	On	1.00	141.24	46.4	148.7	186.60	141.2	46.4	On 148.7	186.60
i		1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
I		0.80	20.00	15.0	25.0	31.38	16.0	12.0	20.0	25.10
		0.00	0.92	0.9	1.3	2.10	0.0	0.0	0.0	0.00
:		0.00	0.92	0.9	1.3	2.10	0.0	0.0	0.0	0.00
		0.70	24.00	18.0	30.0	37.65	16.8	12.6	21.0	26.36
:		1.00	4.24	3.0	5.2	7.60	4.2	3.0	5.2	7.60

- View 4 of 4:
- Calculate connected FLA and running FLA
- Running FLA is more significant since it represents the actual maximum demand from which the power system is sized
- Cannot simply add each kVA because of different PF
- Must sum each column of kW and kVAR
- Calculate kVA = Sq Rt (kW² + kVAR²)
- Calculate Amps = kVA/[Sq Rt (3) x kV]



FORINPUTEATA												
	LOAD			DEM		CONNECT	ED			RUNNING	ì	
	TYPE	LOAD	PF	FACT	K¥-C	KYAR-C	KYA-C	AMPS-C	K¥-B	KYAR-R	KYA-R	AMPS
n East Zone	AFD	350.00	0.95	1.00	326.68	107.4	343.9	431.59	326.7	107.4	343.9	431.59
in East Zone	AFD	350.00	0.95	1.00	326.68	107.4	343.9	431.59	326.7	107.4	343.9	431.59
n West Zone	AFD	200.00	0.95	0.00	186.65	61.3	196.5	246.60	0.0	0.0	0.0	0.00
in West Zone	AFD	200.00	0.95	0.00	186.65	61.3	196.5	246.60	0.0	0.0	0.0	0.00
	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
}	AFD	150.00	0.95	1.00	141.24	46.4	148.7	186.60	141.2	46.4	148.7	186.60
	KVA	25.0	0.80	0.80	20.00	15.0	25.0	31.38	16.0	12.0	20.0	25.10
h, West)	MOTOR	1.00	0.72	0.00	0.92	0.9	1.3	2.10	0.0	0.0	0.0	0.00
h, East)	MOTOR	1.00	0.72	0.00	0.92	0.9	1.3	2.10	0.0	0.0	0.0	0.00
	KVA –	30.00	0.80	0.70	24.00	18.0	30.0	37.65	16.8	12.6	21.0	26.36
	MOTOR	5.00	0.82	1.00	4.24	3.0	5.2	7.60	4.2	3.0	5.2	7.60
	MOTOR	5.00	0.82	0.00	4.24	3.0	5.2	7.60	0.0	0.0	0.0	0.00
	AFD	5.00	0.95	1.00	5.90	1.9	6.2	7.80	5.9	1.9	6.2	7.80
	AFD	5.00	0.95	0.00	5.90	1.9	6.2	7.80	0.0	0.0	0.0	0.00
	KVA	5.00	0.80	0.80	4.00	3.0	5.0	6.28	3.2	2.4	4.0	5.02
	KVA	5.00	0.80	0.80	4.00	3.0	5.0	6.28	3.2	2.4	4.0	5.02
	KVA	5.00	0.80	0.80	4.00	3.0	5.0	6.28	3.2	2.4	4.0	5.02
	MOTOR	0.50	0.60	1.00	0.48	0.6	0.8	1.10	0.5	0.6	0.8	1.10
	KVA	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
	KVA	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
	KVA	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
	KVA	30.00	0.80	0.90	24.00	18.0	30.0	37.65	21.6	16.2	27.0	33.89
01	KVA	28.00	0.80	1.00	22.40	16.8	28.0	35.14	22.4	16.8	28.0	35.14
	KVA	10.00	0.80	1.00	8.00	6.0	10.0	12.55	8.0	6.0	10.0	12.55
	KVA	3.00	0.80	1.00	2.40	1.8	3.0	3.77	2.4	1.8	3.0	3.77
<u>ANENIE</u>)	KVA		0.92	1.00	244.40	101.51	264.64	332.15	185.7	76.6	200.8	252.07
2-CHENÎ)	KVA		0.99	1.00	138.18	24.25	140.29	176.08	135.0	21.6	136.8	171.66
· · · · · · · · · · · · · · · · · · ·				0.00		0.0	0.0	0.00	0.0	0.0	0.0	0.00
					2181.6	799.7	2323.5		1711.2	625.4	1821.9	
CONNECTED FLA		2916.3		P.F	0.939						R /	
BUNNING FLA		2286.7		P.F.	0.939				L		.	
									B	LACK	& VE	ATCH
Page - 48												

System Design: Size Transformer

- B. Size Transformer to 480 V Loads
- From load study, running FLA = 2286.7 A
- Size transformer to accommodate this total load
- kVA = Sq Rt (3) x IFL x kV
- kVA = 1.732 x 2286.7 A x 0.48 kV = 1901 kVA
- Next standard transformer size is 2000 kVA



System Design: Size Transformer



System Design: Size 480 V MCC

- C. Size 480 V Motor Control Center (MCC)
- From load study, running FLA = 2286.7 A
- MCC bus rating = FLA x 125%
- MCC bus rating = 2286.7 A x 1.25 = 2858 A
- Next standard MCC bus size is 3000 A
- MCC main breaker will be fully sized at 3000 A

BUILDING A WORLD OF DIFFERENCE®



System Design: Size 480 V MCC



- D. <u>Select Short Circuit Rating of 480 V MCC</u>
- Very important
- If undersized, could explode and start fire during short circuit conditions
- Danger of arc flash, based on I²T
- Energy released is proportional to the square of the current x the time duration
- Time duration is calculated on clearing time of upstream OCPD, breaker, fuse, relay

- Selection of OCPD at too high a trip setting will delay clearing time
- Selection of OCPD with too long a time delay before trip will delay clearing time
- Both settings will allow the energy from I² to increase
- If electrical equipment is not sized, or braced, for maximum fault current, could explode
- Usually use power systems analysis software like ETAP or SKM to more accurately calculate fault duty at each bus
- Fault duty at each bus then determines minimum short circuit rating of electrical equipment

- Before a short circuit study can be performed using power systems analysis software, a model of the power system must be created
- System modeling parameters include the following:
- Utility short circuit contribution
- - Transformers
- - Motors
- Conductor sizes and lengths
- On-site generation, etc.

BUILDING A WORLD OF DIFFERENCE®



System Design: Sample Power System Model





System Design: Sample Load Flow Study

Load Flow Results Utility Substation USS-A

Bus 3 Phase Totals

Bus Name	In/Out Service	Design Volts	Phase	LF Volts	Angle Degree	PU Volts	%VD
BUS-0004	In	16,340	А	9,433.90	0.00	1.00	0.00
BUS-0021	In	4,160	С	2,331.93	88.27	0.97	2.91
BUS-0022	In	4,160	С	2,331.54	88.28	0.97	2.92
BUS-0062	In	480	А	264.17	-62.23	0.95	4.67
BUS-0064	In	480	А	263.73	-62.34	0.95	4.84
ATS	In	208	А	113.20	-62.96	0.94	5.74

System Design: Load Flow Study Results

- From results of load flow study,
- The voltage at each bus is calculated
- The Vdrop at each bus is also calculated
- The last bus, ATS, shows a Vdrop greater than 5%
- The load flow study can be programmed to automatically display all buses exceeding a Vdrop greater than 5%, or any other threshold



System Design: Sample Short Circuit Study

Short Circuit Results Utility Substation USS-A

Bus Fault Contribution

Transformer Phase Shift Yes

Unbalanced / Single Phase Comprehensive Fault Study Settings

Faulted Bus Selection	Fault All Buses One By One	Motor Contribution	Yes
Fault Current Calculation	RMS	Transformer Tap	Yes

Asym Fault Current at Time 0.50

				Initia	l Symm	etrical]	RMS		- Asvm	RMS	Amps @ 0.5	50 Cycles	3	-Phase	Asvm Ar	nos (RM	S)
Fault Location	Bus L	L	3-Phase	3-Phase	SLG	SLG	LL	LLG	5		3-Phase	SLG	1/2	2	3	1 <u>5</u>	8
Bus Name	Volta;	ge	Amps	MVA	Amps	MVA	Amps	Amps	X/]	R	Amps	Amps	Cycle	Cycles	Cycles	Cycles	Cycles
BUS-0004	16 340	۵·	1 503	14 18	001	8 50	0	0	3 D·	2 12	1 580	1 019	1 580	1 503	1 503	1 503	1 503
202-0004	10,040	B.	1 503	14 18	0	0.00	ň	ň	SLG:	3 10	1 580	1,019	1 580	1 503	1 503	1 503	1 503
		Ĉ:	1,503	14.18	Ŏ	0.00	ŏ	ŏ	LLG:	INF	1,580	ŏ	1,580	1,503	1,503	1,503	1,503
BUS-0021	4,160	A:	2,478	5.95	2,846	6.84	0	0	3P:	3.74	2,903	3,415	2,903	2,481	2,478	2,478	2,478
	.,	B:	2,478	5.95	-,	0.00	Ō	Ó	SLG:	4.15	2,903	0	2,903	2,481	2,478	2,478	2,478
		C:	2,478	5.95	0	0.00	0	0	LLG:	INF	2,903	0	2,903	2,481	2,478	2,478	2,478
BUS-0022	4,160	A:	2,431	5.84	2,763	6.64	0	0	3P:	3.36	2,779	3,199	2,779	2,432	2,431	2,431	2,431
		B:	2,431	5.84	· 0	0.00	0	0	SLG:	3.55	2,779	0	2,779	2,432	2,431	2,431	2,431
		C:	2,431	5.84	0	0.00	0	0	LLG:	INF	2,779	0	2,779	2,432	2,431	2,431	2,431
BUS-0062	480	A:	5,583	1.55	6,183	1.71	0	0	3 P:	5.80	7,231	8,313	7,231	5,656	5,592	5,583	5,583
		B :	835, 5	1.55	0	0.00	0	0	SLG:	6.93	7,231	0	7,231	5,656	5,592	83کړ ک	5,583
		C:	5,583	1.55	0	0.00	0	0	LLG:	INF	7,231	0	7,231	5,656	5,592	5,583	5,583
BUS-0064	480	A:	5,047	1.40	5,531	1.53	0	0	3P:	6.17	6,624	7,524	6,624	5,132	5,058	5,047	5,047
		B :	5,047	1.40	0	0.00	0	0	SLG:	7.35	6,624	0	6,624	5,132	5,058	5,047	5,047
		C:	5,047	1.40	0	0.00	0	0	LLG:	INF	6,624	0	6,624	5,132	5,058	5,047	5,047
ATS	208	A:	3,850	0.46	3,605	0.43	0	0	3P:	3.95	4,569	3,980	4,569	3,857	3,851	3,850	3,850
		В:	3,850	0.40	U	0.00	U	U	SLG:	2.84	4,509	U	4,009	3,857	3,851	3,850	3,850
		C:	5,850	U.46	0	0.00	0	0	LLG:	INF	4,569	U	692, 4	5,857	3,851	3,850	3,850
BUS-0023	4,160	A:	2,373	5.70	2,665	6.40	0	0	3P:	3.00	2,649	2,983	2,649	2,374	2,373	2,373	2,373
Pa	-	B :	2,373	5.70	0	0.00	0	0	SLG:	3.04	2,649	0	2,649	2,374	2,373	2,373	2,373

System Design: Sample Short Circuit Study

				Initia	l Symm	etrical	.RMS
Fault Location	Bus LI		3-Phase	3-Phase	SLG	SLG	\mathbf{LL}
Bus Name	Voltag	e	Amps	MVA	Amps	MVA	Amps
BUS-0004	16,340	A:	1,503	14.18	901	8.50	0
		B: C:	03کر1 03کر1	14.18 14.18	0 0	0.00 0.00	0 0
BUS-0021	4,160	A:	2,478	5.95	2,846	6.84	0
		B: C:	2,478 2,478	5.95 5.95	0 0	0.00 0.00	0 0
BUS-0022	4,160	A:	2,431	5.84	2,763	6.64	0
	ŕ	B: C:	2,431 2,431	5.84 5.84	0 0	0.00 0.00	0 0
BUS-0062	480	A:	5,583	1.55	6,183	1.71	0
		в: С:	۶۶۵ 5,583	1.55	0	0.00 0.00	U 0
BUS-0064	4 80	A :	5,047	1.40	5,531	1.53	0
		в: С:	5,047 5,047	1.40	0	0.00	0
ATS	208	A:	3,850	0.46	3,605	0.43	0
		в: С:	3,850 3,850	0.40 0.46	U 0	0.00 0.00	υ 0

- From results of SKM short circuit study, the fault duty at the 480 V bus = 5,583 A
- This particular power system had a very low fault duty contribution from the utility
- This low fault duty shows up at all downstream buses
- Select next available short circuit rating for a 480 V MCC

- If power systems analysis software is not available, can use a conservative approximation
- The "MVA method" represents the worst case fault current thru transformer
- Transformers naturally limit the current thru transformer to secondary bushings
- Need transformer impedance, or assume typical is 5.75%Z, plus or minus
- Assume utility supply can provide infinite short circuit amperes to transformer primary (i.e., substation across the street)

• MVA method calculation:

- Where, Isc = Short Circuit Current
- kV = Transformer secondary voltage rating
- For this example with a 2000 kVA transformer,

2000 kVA Isc = ------ = 41,838 A Sq Rt (3) x .48 kV x 0.0575

 Select next available short circuit rating for a standard 480 V MCC = 65,000 A

- E. Size 480 V Feeder from Transformer to MCC
- First calculate IFL from transformer secondary

 $IFL = \frac{1}{Sq Rt (3) x kV}$ $IFL = \frac{2000 kVA}{Sq Rt (3) x 0.48 kV}$

- IFL x 125% = 2405.7 A x 1.25 = 3007 A
- No one makes a cable to handle 3000 A

- Must use parallel sets of conductors
- Each conduit will have A, B, C, and GND cables, plus neutral if required for 1-phase loads
- Standard engineering practice is to use 500 kcmil (253 mm²) or 600 kcmil (304 mm²) conductors
- Why?
- Largest standard conductor that will fit easily into a standard 103 mm² conduit
- For this example, we will use 500 kcmil (253 mm²)



NEC Table 310.16, Conductor Ampacity

Size AWG or kcmil	Types TW, UF	Types RHW, THHW, THW, THWN, XHHW, USE, ZW	Types TBS, SA, SIS, FEP, FEPB, MI, RHH, RHW-2, THHN, THHW, THW-2, THWN-2, USE-2, XHH, XHHW, XHHW-2, ZW-2
		COPPER	
18 16 14* 12* 10* 8	20 25 30 40	20 25 35 50	14 18 25 30 40 55
6 4 3 2 1	55 70 85 95 110	65 85 100 115 130	75 95 110 130 150
1/0 2/0 3/0 4/0	125 145 165 195	150 175 200 230	170 195 225 260
250 300 350 400 500	215 240 260 280 320	255 285 310 335 380	290 320 350 380 430
600	355	420	475

- Per NEC Table 310.16,
- A single 500 kcmil (253 mm²) conductor has an ampacity of 380 A
- Calculate quantity of parallel sets:
- Parallel sets = Target Ampacity/Conductor Ampacity
- Parallel sets = 3007 A/380 A = 7.91
- Round up to 8 parallel sets of 3-500 kcmil (253 mm²)
- Select grounding conductor

NEC Table 250.122, Grounding Conductors

Table 250.122 Minimum Size Equipment Grounding Conductors for Grounding Raceway and Equipment

Rating or Setting of Automatic Overcurrent	Size (AWG or kcmil)						
of Equipment, Conduit, etc., Not Exceeding (Amperes)	Copper	Aluminum or Copper-Clad Aluminum*					
15	14	12					
20	12	10					
30	10	8					
40	10	8					
60	10	8					
100	8	6					
200	6	4					
300	4	2					
400	3	1					
500	2	1/0					
600	1	2/0					
800	1/0	3/0					
1000	2/0	4/0					
1200	3/0	250					
1600	4/0	350					
2000	250	400					
2500	350	600					
3000	400	600					

- Select grounding conductor
- Per NEC Table 250.122,
- Based on 3000 A trip rating
- Grounding conductor = 400 kcmil (203 mm²)

- Total cables = 8 sets of 3-500 kcmil (253 mm²), 1-400 kcmil (203 mm²) GND
- Or, total 24-500 kcmil (253 mm²), 8-400 kcmil (203 mm²) GND

- Calculate total cross-sectional area of each set of cables
- Per NEC Chapter 9, Table 5, for XHHW cables
- Area of 500 kcmil (253 mm²) cable = 450.6 mm²
- Area of 400 kcmil (203 mm²) cable = 373.0 mm²
- Total cross-sectional area of each parallel set = 3 x 450.6 mm² + 1 x 373.0 mm² = 1724.8 mm²
- Select conduit to maintain FF < 40%

Sine (AWC	Approximate	Diameter	Approximat	e Area
kcmil)	mm	in.	mm^2	in. ²
Туре	: KF-1, KF-2, KF	F-1, KFF-2, XHH, X	HHW, XHHW-2, ZW	
14	3.378	0.133	8,968	0.0139
12	3.861	0.152	11.68	0.0181
10	4.470	0.176	15.68	0.0243
8	5.994	0.236	28.19	0.0437
6	6.960	0.274	38.06	0.0590
4	8.179	0.322	52.52	0.0814
3	8.890	0.350	62.06	0.0962
2	9.703	0.382	73.94	0.1146
1	11.23	0.442	98.97	0.1534
1/0	12.24	0.482	117.7	0.1825
2/0	13.41	0.528	141.3	0.2190
3/0	14.73	0.58	170.5	0.2642
4/0	16.21	0.638	206.3	0.3197
250	17.91	0.705	251.9	0.3904
300	19.30	0.76	292.6	0.4536
350	20.60	0.811	333.3	0.5166
400	21.79	0.858	373.0	0.5782
500	23.95	0.943	450.6	0.6984
	Size (AWG or kemil) Type 14 12 10 8 6 4 3 2 1 1 1/0 2/0 3/0 4/0 250 300 350 400 500	$\begin{tabular}{ c c c c c } \hline Approximate \\ \hline Size (AWG or $$ mm$ \\ \hline mm$ \\ \hline Type: KF-1, KF-2, KF. \\ \hline 14 & 3.378 \\ 12 & 3.861 \\ 10 & 4.470 \\ 8 & 5.994 \\ 6 & 6.960 \\ 4 & 8.179 \\ 3 & 8.890 \\ 2 & 9.703 \\ \hline 1 & 11.23 \\ \hline 1/0 & 12.24 \\ 2/0 & 13.41 \\ 3/0 & 14.73 \\ 4/0 & 16.21 \\ \hline 250 & 17.91 \\ 300 & 19.30 \\ 350 & 20.60 \\ \hline 400 & 21.79 \\ 500 & 23.95 \\ \hline \end{tabular}$	$\begin{tabular}{ c c c c c c } \hline Approximate Diameter \\ \hline Size (AWG or $$mm$ in.$$ $$mm$ in.$ $$ $$Type: KF-1, KF-2, KFF-1, KFF-2, XHH, X$ $$14 $$3,378 $$0,133 $$12 $$3,861 $$0,152 $$10 $$4,470 $$0,176 $$$3,861 $$0,152 $$10 $$4,470 $$0,176 $$$$6 $$6,960 $$0,274 $$4 $$8,179 $$0,322 $$3 $$8,890 $$0,350 $$2 $$9,703 $$0,382 $$$$$$0,382 $$$11 $$11,23 $$0,442 $$$170 $$12,24 $$0,482 $$2/0 $$13,41 $$0,528 $$3/0 $$14,73 $$0,58 $$$$$$4/0 $$16,21 $$0,638 $$$$$$$$$$250 $$17,91 $$0,705 $$300 $$19,30 $$0,76 $$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$	$\begin{tabular}{ c c c c c c c c c c c c c c c c c c c$

NEC Chapter 9, Table 4, RMC Conduit Dimensions

		Article 344 — Rigid Metal Condu								
Metric Designator	Trade Size	Nominal Internal Diameter		Total Area 100%		60%		1 W 53	1 Wire 53%	
		mm	in.	mm ²	in. ²	mm ²	in. ²	mm^2	in. ²	
12	3⁄8								_	
16	1/2	16.1	0.632	204	0.314	122	0.188	108	0.166	
21	3/4	21.2	0.836	353	0.549	212	0.329	187	0.291	
27	1	27.0	1.063	573	0.887	344	0.532	303	0.470	
35	11/4	35.4	1.394	984	1.526	591	0.916	522	0.809	
41	11/2	41.2	1.624	1333	2.071	800	1.243	707	1.098	
53	2	52.9	2.083	2198	3.408	1319	2.045	1165	1.806	
63	21/2	63.2	2.489	3137	4.866	1882	2.919	1663	2.579	
78	3	78.5	3.090	4840	7.499	2904	4.499	2565	3.974	
91	31/2	90.7	3.570	6461	10.010	3877	6.006	3424	5.305	
103	4	102.9	4.050	8316	12.882	4990	7.729	4408	6.828	
129	5	128.9	5.073	13050	20.212	7830	12.127	6916	10.713	
155	6	154.8	6.093	18821	29.158	11292	17.495	9975	15.454	
System Design: 480 V Feeder from Transf to MCC

- Per NEC Chapter 9, Table 4:
- For RMC, a conduit diameter of 103 mm has an area of 8316 mm²
- Fill Factor = 1724.8 mm²/8316 mm² = 20.7%
- FF < 40%, OK
- For large cables in one conduit, it is not recommended to approach the FF = 40% due to the excessive pulling tensions when installing the cables

NEC Chapter 9, Table 4, PVC Conduit Dimensions

Metric Designator	Trade Size	Nominal Internal Diameter		Total 10	Area 0%	60%		1 Wire 53%	
		mm	in.	mm^2	in. ²	mm^2	in. ²	mm ²	in. ²
12	3∕8							_	
16	1/2	15.3	0.602	184	0.285	110	0.171	97	0.151
21	3⁄4	20.4	0.804	327	0.508	196	0.305	173	0.269
27	1	26.1	1.029	535	0.832	321	0.499	284	0.441
35	11/4	34.5	1.360	935	1.453	561	0.872	495	0.770
41	11/2	40.4	1.590	1282	1.986	769	1.191	679	1.052
53	2	52.0	2.047	2124	3.291	1274	1.975	1126	1.744
63	21/2	62.1	2.445	3029	4.695	1817	2.817	1605	2.488
78	3	77.3	3.042	4693	7.268	2816	4.361	2487	3.852
91	31/2	89.4	3.521	6277	9.737	3766	5.842	3327	5.161
103	4	101.5	3.998	8091	12.554	4855	7.532	4288	6.654
129	5	127.4	5.016	12748	19.761	7649	11.856	6756	10.473
155	6	153.2	6.031	18433	28.567	11060	17.140	9770	15.141

System Design: 480 V Feeder from Transf to MCC

- Per NEC Chapter 9, Table 4:
- For PVC, a conduit diameter of 103 mm has an area of 8091 mm²
- Fill Factor = 1724.8 mm²/8091 mm² = 21.3%
- FF < 40%, OK

Final Feeder: 8 sets each of 103 mm² conduit, 3-500 kcmil (253 mm²), 1-400 kcmil (203 mm²) GND

- F. <u>Size Transformer 12 kV Primary Disconnect</u>
- First calculate IFL from transformer primary

 $IFL = \frac{Transformer kVA}{Sq Rt (3) x kV}$ $\frac{2000 kVA}{IFL = \frac{96.2 A}{Sq Rt (3) x 12 kV}}$

• IFL x 125% = 96.2 A x 1.25 = 120.3 A

- Most common 12 kV disconnect devices are:
- a) Metal-enclosed fused load interrupter switches
- b) Metal-clad vacuum breaker switchgear with OCPD, or relay

BUILDING A WORLD OF DIFFERENCE®



System Design: Transformer 12 kV Disconnect



Page - 78

BUILDING A WORLD OF DIFFERENCE®





- Minimum bus rating of metal-enclosed fused load interrupter switches = 600 A
- Bus rating > IFL x 125%
- 600 A > 120.3 A, OK

- Minimum bus rating of metal-clad vacuum breaker switchgear = 1200 A
- Bus rating > IFL x 125%
- 1200 A > 120.3 A, OK

- Size fuse for OCPD with metal-enclosed fused load interrupter switches
- NEC governs maximum size of fuses for transformer protection
- NEC Table 450.3(A), Maximum Rating or Setting of Overcurrent Protection for Transformers Over 600 Volts (as a Percentage of Transformer-Rated Current)
- For transformer IFL = 96.2 A

Table 450.3(A) Maximum Rating or Setting of Overcurrent Protection for Transformers Over 600 Volts (as a Percentage of Transformer-Rated Current)

		D: D (Secondary Protection (See Note 2.)						
		Primary Protec	tion over 600 ts	Over 600	600 Volts or Less					
Location Limitations	Transformer Rated Impedance	Circuit Breaker (See Note 4.)	Fuse Rating	Circuit Breaker (See Note 4.)	Fuse Rating	Circuit Breaker or Fuse Rating				
Any location	Not more than 6%	600% (See Note 1.)	300% (See Note 1.)	300% (See Note 1.)	250% (See Note 1.)	125% (See Note 1.)				
	More than 6% and not more than 10%	400% (See Note 1.)	300% (See Note 1.)	250% (See Note 1.)	225% (See Note 1.)	125% (See Note 1.)				
Supervised locations only (See Note 3.)	Any	300% (See Note 1.)	250% (See Note 1.)	Not required	Not required	Not required				
	Not more than 6%	600%	300%	300% (See Note 5.)	250% (See Note 5.)	250% (See Note 5.)				
	More than 6% and not more than 10%	400%	300%	250% (See Note 5.)	225% (See Note 5.)	250% (See Note 5.)				

- Per NEC Table 450.3(A),
- For transformer typical impedance = 5.75%
- Maximum size fuse = IFL x 300%
- Maximum size fuse = 96.2 A x 3.0 = 288.7 A
- NEC allows next higher size available
- Thus, fuse = 300 A
- Although NEC dictates maximum, standard engineering practice is to select fuse at IFL x 125% = 120.3 A, or round up to 150 A

- Select OCPD relay trip setting with metal-clad vacuum breaker switchgear
- NEC governs maximum relay trip setting for transformer protection
- NEC Table 450.3(A), Maximum Rating or Setting of Overcurrent Protection for Transformers Over 600 Volts (as a Percentage of Transformer-Rated Current)
- For transformer IFL = 96.2 A

Table 450.3(A) Maximum Rating or Setting of Overcurrent Protection for Transformers Over 600 Volts (as a Percentage of Transformer-Rated Current)

		D: D (Secondary Protection (See Note 2.)						
		Primary Protect	tion over 600	Over 60	600 Volts or Less					
Location Limitations	Transformer Rated Impedance	Circuit Breaker (See Note 4.)	Fuse Rating	Circuit Breaker (See Note 4.)	Fuse Rating	Circuit Breaker or Fuse Rating				
Any location	Not more than 6%	600% (See Note 1.)	300% (See Note 1.)	300% (See Note 1.)	250% (See Note 1.)	125% (See Note 1.)				
	More than 6% and not more than 10%	400% (See Note 1.)	300% (See Note 1.)	250% (See Note 1.)	225% (See Note 1.)	125% (See Note 1.)				
Supervised locations only (See Note 3.)	Any	300% (See Note 1.)	250% (See Note 1.)	Not required	Not required	Not required				
	Not more than 6%	600%	300%	300% (See Note 5.)	250% (See Note 5.)	250% (See Note 5.)				
	More than 6% and not more than 10%	400%	300%	250% (See Note 5.)	225% (See Note 5.)	250% (See Note 5.)				

- Per NEC Table 450.3(A),
- For transformer typical impedance = 5.75%
- Maximum relay trip setting = IFL x 600%
- Maximum relay trip setting = 96.2 A x 6.0 = 577.4 A
- NEC allows next higher relay trip setting available
- Thus, relay trip setting = 600 A
- Although NEC dictates maximum, standard engineering practice is to set relay trip setting at IFL x 125% = 120.3 A

- In order to calculate the proper relay settings, the current transformer (CT) turns ratio must be selected
- The turns ratio of the CT is based on the maximum expected current = IFL = 96.2 A
- This could be a 100:5 CT, such that when the CT senses 100 A on the 12 kV cable, it outputs 5 A on the CT secondary for direct input into the relay
- However, saturation of the CT should be avoided in case the transformer must temporarily supply power greater than its nameplate rating

- Standard engineering practice is to size the CT such that the expected maximum current is about 2/3 of the CT ratio
- For this transformer IFL = 96.2 A
- The 2/3 point = 96.2 A/(2/3) = 144.3 A
- Select next standard available CT ratio of 150:5

- For many years the most common type of overcurrent relay was an induction disk type of relay
- Depending on the secondary CT current input to the relay, the disk would rotate a corresponding angle
- Today's technology uses electronic-based relays
- As such, electronic relays are more accurate in sensing pick-up and contain smaller incremental gradations of available settings than induction disk relays

- For example: Induction disk relays had available tap settings in increments of 1 A or 0.5 A
- Today's electronic relays have tap settings in increments of 0.01 A
- Thus, a more exact tap setting could be selected, thereby making coordination with upstream and downstream devices much easier

System Design: Surge Protection at Transformer

- G. <u>Select Surge Protection at Transformer Primary</u>
- Prudent to install surge arresters at line side terminals of transformer for protection
- Helps to clip high voltage spikes or transients from utility switching or lightning strikes
- Should be about 125% of nominal supply voltage from utility
- Don't want to be too close to nominal utility supply voltage
- Must allow utility voltage supply variations

System Design: Surge Protection at Transformer

- Example, for delta circuit, most common:
- Utility Nominal Supply Voltage x 125%
- 12 kV x 1.25% = 15 kV
- Thus, surge arrester voltage rating = 15 kV, minimum
- Could select higher voltage if utility has widely varying voltage supply
- Surge arrester is connected phase-to-ground

System Design: Surge Protection at Transformer

- If wrong selection of 8.6 kV surge arrester on 12 kV circuit, then the surge arrester would probably explode upon energization because it will shunt to ground any voltage higher than 8.6 kV
- The switchgear would be under short circuit conditions and the fuse would blow or the relay would trip

- H. <u>Size 12 kV Feeder to Transformer (MV Cable)</u>
- Sizing 15 kV conductors for 12 kV circuits still uses transformer IFL = 96.2 A
- IFL x 125% = 96.2 A x 1.25 = 120.3 A
- Select conductor size based on NEC tables
- Similar to 600 V cables, depends on aboveground or underground installation for Medium Voltage (MV) cable

- One of the more popular 15 kV cables is rated as follows:
- - 15 kV, 100% or 133% insulation
- 15 kV with 133% insulation = 15 kV x 1.33 = 20 kV (optional rating for circuit voltages between 15 kV and 20 kV)
- MV-105 = medium voltage cable, rated for 105°C conductor temperature (previous rating was MV-90, and had lower ampacity)

- EPR insulation = Ethylene Propylene Rubber insulation (traditional insulation versus newer crosslinked polyethylene, or XLP)
- - Cu = copper conductor
- Shielded = Copper tape wrapped around EPR insulation (to aid in containing electric field and an immediate ground fault return path)
- - PVC jacket = overall jacket around cable

BUILDING A WORLD OF DIFFERENCE®



System Design: Okonite 15 kV Cable

THE OKONITE COMPANY

Product Data Section 2: Sheet 9

COMPACT STRAND CONSTRUCTION

Okoguard®-Okoseal® Type MV-105 15kV Shielded Power Cable

One Okopact[®] (Compact Stranded) Copper Conductor/105°C Rating 100% and 133% Insulation Level

(YL



A Uncoated, Okopact (Compact Stranded) Copper Conductor

B Strand Screen-Extruded Semiconducting EPR

C Insulation-Okoguard EPR

D Insulation Screen-Extruded semiconducting EPR

E Shield-Copper Tape

F Jacket Okoseal

Insulation

Okoguard is Okonite's registered trade name for its exclusive ethylene-propylene rubber (EPR) based, thermosetting compound,



System Design: Okonite 15 kV Cable



- For aboveground applications, use NEC Table 310.73
- NEC Table 310.73 = Ampacities of an Insulated Triplexed or Three Single-Conductor Copper Cables in Isolated Conduit in Air Based on Conductor Temperature of 90°C (194°F) and 105°C (221°F) and Ambient Air Temperature of 40°C (104°F)
- For IFL x 125% = 120.3 A



Table 310.73 Ampacities of an Insulated Triplexed or Three Single-Conductor Copper Cables in Isolated Conduit in Air Based on Conductor Temperatures of 90°C (194°F) and 105°C (221°F) and Ambient Air Temperature of 40°C (104°F)

	Temperature Rating of Conductor [See Table 310.13(C).]										
	2001– An	5000 Volts npacity	5001–35,000 Volts Ampacity								
Conductor Size (AWG or kcmil)	90°C (194°F) Type MV-90	105°С (221°F) Туре MV-105	90°C (194°F) Type MV-90	105°С (221°F) Туре MV-105							
8	55 75	61 84	83	93							
4 2	97 130	110 145 175	110 150	120 165							
1/0 2/0 3/0 4/0	180 205 240 280	200 225 270 305	195 225 260 295	215 255 290 330							
250 350 500 750 1000	315 385 475 600 690	355 430 530 665 770	330 395 480 585 675	365 440 535 655 755							

- Per NEC Table 310.73, for 15 kV, MV-105,
- 4 AWG (21.15 mm²) ampacity = 120 A
- 2 AWG (33.62 mm²) ampacity = 165 A
- 4 AWG (21.15 mm²) is not a common size in 15 kV cables
- 2 AWG (33.62 mm²) is much more common and available
- Thus, select 2 AWG (33.62 mm²) for phase conductors

- Select grounding conductor
- Use NEC Table 250.122
- Relay trip setting would be set to 120 A, so overcurrent rating would be 200 A per NEC table

NEC Table 250.122, Grounding Conductors

Table 250.122 Minimum Size Equipment Grounding Conductors for Grounding Raceway and Equipment

Rating or Setting of Automatic Overcurrent	Size (AWG or kcmil)						
of Equipment, Conduit, etc., Not Exceeding (Amperes)	Copper	Aluminum or Copper-Clad Aluminum*					
15	14	12					
20	12	10					
30	10	8					
40	10	8					
60	10	8					
100	8	6					
200	6	4					
300	4	2					
400	3	1					
500	2	1/0					
600	1	2/0					
800	1/0	3/0					
1000	2/0	4/0					
1200	3/0	250					
1600	4/0	350					
2000	250	400					
2500	350	600					
3000	400	600					
	. = =						

- Per NEC Table 250.122,
- Grounding conductor is 6 AWG (13.30 mm²)
- Does grounding cable for 12 kV circuit need to be rated for 15 kV, same as phase cables?
- No.
- Grounding conductor is not being subject to 12 kV voltage
- Circuit = 3-2 AWG (33.62 mm²), 15 kV, 1-6 AWG (13.30 mm²) GND

- Select conduit size for 12 kV circuit
- For 15 kV cables, use Okonite data sheet

BUILDING A WORLD OF DIFFERENCE®



1-Catalog Number 2-Conductor Size - AWG or Jonal 3-Conductor Size - mm2 4-Approx. Dia. over Insulation(m.) 5-Approx. Dia. over Screen(m.) 6-Jacket Thickness - mils 7-Jacket Thickness - mm 8-Approx. 0. B Inches					09-Approx. O.D mm 10-Approx. Net Weight Dos /1000' 11-Approx. Ship Weight Dos /1000' 12-Ampacities Conduit in Air() 13-Ampacities Direct Bunial() 14-Ampacities Underground Duct() 15-Conduit Size-Inches '(4)									
1 2 3 4 5 6					7	8	9	10	11	12	13	14	15	
Okoguard In	sulation:	175 mi	ls(4.4	45mn	a), 10	00%	Insul	ation	Leve	el				
115-23-3011	2	33.6	0.66	0.72	80	2.03	0.91	23.0	585	655	165	225	165	3
115-23-3013	1	42.4	0.69	0.75	80	2.03	0.94	23.8	660	755	190	260	185	3
115-23-3015	1/0	53.5	0.73	0.79	80	2.03	0.98	24.8	750	845	215	295	215	3
115-23-3017	2/0	67.4	0.77	0.83	80	2.03	1.02	25.8	860	955	255	335	245	3
115-23-3019	3,0	85.0	0.82	0.88	80	2.03	1.06	27.0	995	1090	290	380	275	3
115-23-3021	4,0	107.0	0.87	0.93	80	2.03	1.12	28.3	1160	1260	330	435	315	3
115-23-3023	250	127.0	0.91	0.97	80	2.03	1.16	29.4	1310	1425	365	475	345	3 1/2
115-23-3027	350	177.0	1.01	1.07	80	2.03	1.26	32.0	1675	1815	440	575	415	3 1/2
115-23-3031	500	253.0	1.13	1.21	80	2.03	1.39	35.4	2230	2425	535	700	500	4
115-23-3035	750	380.0	1.31	1.39	80	2.03	1.58	40.0	3300	3565	655	865	610	5
115-23-3037	1000	507.0	1.47	1.55	110	2.79	1.79	45.6	4095	4365	755	1005	690	5
Okoguard In	sulation:	220 mi	ls(5.5	59mn	a), 1	33%	Insul	ation	Leve	el 🛛				
▲115-23-3111	2	33.6	0.75	0.81	80	2.03	1.00	25.3	670	765	165	225	165	3
115-23-3113	1	42.4	0.78	0.84	80	2.03	1.03	26.1	745	840	190	260	185	3
A 115-23-3115	1/0	53.5	0.82	0.88	80	2.03	1.07	27.1	840	915	215	295	215	3
A 115-23-3117	2/0	67.4	0.86	0.92	80	2.03	1.11	28.1	955	1050	255	335	245	3
115-23-3119	3/0	85.0	0.91	0.97	80	2.03	1.16	29.3	1090	1190	290	380	275	3 1/2
A 115-23-3121	4/0	107.0	0.96	1.02	80	2.03	1.21	30.7	1265	1375	330	435	315	3 1/2
▲115-23-3123	250	127.0	1.01	1.07	80	2.03	1.25	31.8	1415	1550	365	475	345	3 1/2
A115-23-3127	350	177.0	1.11	1.18	80	2.03	1.37	34.7	1810	1950	440	575	415	4
▲115-23-3131	500	253.0	1.22	1.30	80	2.03	1.49	37.7	2355	2555	535	700	500	5
▲115-23-3135	750	380.0	1.40	1.48	80	2.03	1.66	42.2	3246	3511	655	865	610	5
A 115-23-3139	1000	507.0	1.56	1.66	110	2.79	1.91	48.5	4290	4705	755	1005	690	6

- For Okonite 100% insulation, cable outer diameter = 23.0 mm
- Cable cross-sectional area = Pi x d²/4
- Cable cross-sectional area = 3.14 x 23.0 mm²/4
- Cable cross-sectional area = 415.5 mm²
- For Okonite 133% insulation, cable outer diameter = 25.3 mm
- Cable cross-sectional area = Pi x d²/4
- Cable cross-sectional area = 3.14 x 25.3 mm²/4
- Cable cross-sectional area = 502.7 mm²

- For grounding conductor = 6 AWG (13.30 mm²)
- Use NEC Chapter 9, Table 5, XHHW Insulation



	Sine (AWC	Approximate	Diameter	Approximate Area		
Туре	kcmil)	mm	in.	mm^2	in. ²	
	Туре	: KF-1, KF-2, KF	F-1, KFF-2, XHH, X	HHW, XHHW-2, ZW		
XHHW, ZW,	14	3.378	0.133	8,968	0.0139	
XHHW-2, XHH	12	3.861	0.152	11.68	0.0181	
	10	4.470	0.176	15.68	0.0243	
	8	5.994	0.236	28.19	0.0437	
	6	6.960	0.274	38.06	0.0590	
	4	8.179	0.322	52.52	0.0814	
	3	8.890	0.350	62.06	0.0962	
	2	9.703	0.382	73.94	0.1146	
XHHW, XHHW-2, XHH	1	11.23	0.442	98.97	0.1534	
	1/0	12.24	0.482	117.7	0.1825	
	2/0	13.41	0.528	141.3	0.2190	
	3/0	14.73	0.58	170.5	0.2642	
	4/0	16.21	0.638	206.3	0.3197	
	250	17.91	0.705	251.9	0.3904	
	300	19.30	0.76	292.6	0.4536	
	350	20.60	0.811	333.3	0.5166	
	400	21.79	0.858	373.0	0.5782	
	500	23.95	0.943	450.6	0.6984	
	L					

- Per NEC Chapter 9, Table 5, for 6 AWG (13.30 mm²)
- Cable cross-sectional area = 38.06 mm²

- Total cable cross-sectional area with 15 kV, <u>100%</u> insulation = 3 x 415.5 mm² + 1 x 38.06 mm² = 1246.4 mm²
- Total cable cross-sectional area with 15 kV, <u>133%</u> insulation = 3 x 502.7 mm² + 1 x 38.06 mm² = 1508.1 mm²
- Select conduit for FF < 40%

NEC Chapter 9, Table 4, RMC Conduit Dimensions

		Article 344 — Rigid Metal C								
Metric Designator	Trade Size	Nominal Internal Diameter		Total Area 100%		60%		1 W 53	1 Wire 53%	
		mm	in.	mm ²	in. ²	mm ²	in. ²	mm ²	in. ²	
12	3/8						_			
16	1/2	16.1	0.632	204	0.314	122	0.188	108	0.166	
21	3/4	21.2	0.836	353	0.549	212	0.329	187	0.291	
27	1	27.0	1.063	573	0.887	344	0.532	303	0.470	
35	11/4	35.4	1.394	984	1.526	591	0.916	522	0.809	
41	11/2	41.2	1.624	1333	2.071	800	1.243	707	1.098	
53	2	52.9	2.083	2198	3.408	1319	2.045	1165	1.806	
63	21/2	63.2	2.489	3137	4.866	1882	2.919	1663	2.579	
78	3	78.5	3.090	4840	7.499	2904	4.499	2565	3.974	
91	31/2	90.7	3.570	6461	10.010	3877	6.006	3424	5.305	
103	4	102.9	4.050	8316	12.882	4990	7.729	4408	6.828	
129	5	128.9	5.073	13050	20.212	7830	12.127	6916	10.713	
155	6	154.8	6.093	18821	29.158	11292	17.495	9975	15.454	

System Design: 480 V Feeder from Transf to MCC

- Per NEC Chapter 9, Table 4:
- For RMC, a conduit diameter of 78 mm has an area of 4840 mm²
- For 15 kV, 100% insulation:
- Fill Factor = 1246.4 mm²/4840 mm² = 25.8%
- FF < 40%, OK

System Design: 480 V Feeder from Transf to MCC

- Per NEC Chapter 9, Table 4:
- For RMC, a conduit diameter of 78 mm has an area of 4840 mm²
- For 15 kV, 133% insulation:
- Fill Factor = 1508.1 mm²/4840 mm² = 31.2%
- FF < 40%, OK



- For underground applications, use NEC Table 310.77
- NEC Table 310.77 = Ampacities of Three Insulated Copper in Underground Electrical Ductbanks (Three Conductors per Electrical Duct) Based on Ambient Earth Temperature of 20°C (68°F), Electrical Duct Arrangement per Figure 310.60, 100 Percent Load Factor, Thermal Resistance (RHO) of 90, Conductor Temperatures of 90°C (194°F) and 105°C (221°F)
- For IFL x 125% = 120.3 A



Table 310.77 Ampacities of Three Single-Insulated Copper Conductors in Underground Electrical Ducts (Three Conductors per Electrical Duct) Based on Ambient Earth Temperature of 20°C (68°F), Electrical Duct Arrangement per Figure 310.60, 100 Percent Load Factor, Thermal Resistance (RHO) of 90, Conductor Temperatures of 90°C (194°F) and 105°C (221°F)

	Temperature Rating of Conductor [See Table <u>310.13(C)</u> .]						
	2001–50 Amp	000 Volts bacity	5001–35,000 Volts Ampacity				
Conductor Size (AWG or kcmil)	90°C (194°F) Type MV-90	105°C (221°F) Type MV-105	90°C (194°F) Type MV-90	105°C (221°F) Type MV-105			
One Circuit (See l 310.60, Detail 1.)	Figure						
. 8	64	69	_	_			
6	85	92	90	97			
4	110	120	115	125			
2	145	155	155	165			
1	170	180	175	185			
1/0	195	210	200	215			
2/0	220	235	230	245			
3/0	250	270	260	275			
4/0	290	310	295	315			
250	320	345	325	3.45			
350	385	415	390	415			
500	470	505	465	500			
750	585	630	565	610			
1000	670	720	640	690			

- Per NEC Table 310.77, for 15 kV, MV-105,
- 4 AWG (21.15 mm²) ampacity = 125 A
- 2 AWG (33.62 mm²) ampacity = 165 A
- 4 AWG (21.15 mm²) is not a common size in 15 kV cables
- 2 AWG (33.62 mm²) is much more common and available
- Thus, select 2 AWG (33.62 mm²) for phase conductors

- Per NEC Table 250.122,
- Grounding conductor is still 6 AWG (13.30 mm²)
- Circuit = 3-2 AWG (33.62 mm²), 15 kV, 1-6 AWG (13.30 mm²) GND

- Select conduit size for 12 kV circuit
- For 15 kV cables, use Okonite data sheet
- Same as for RMC conduit

- For grounding conductor = 6 AWG (13.30 mm²)
- Use NEC Chapter 9, Table 5, XHHW Insulation
- Same as for RMC conduit

- Per NEC Chapter 9, Table 5, for 6 AWG (13.30 mm²)
- Cable cross-sectional area = 38.06 mm²

- Total cable cross-sectional area with 15 kV, <u>100%</u> insulation = 3 x 415.5 mm² + 1 x 38.06 mm² = 1246.4 mm²
- Total cable cross-sectional area with 15 kV, <u>133%</u> insulation = 3 x 502.7 mm² + 1 x 38.06 mm² = 1508.1 mm²
- Select conduit for FF < 40%

NEC Chapter 9, Table 4, PVC Conduit Dimensions

Metric Designator	Matria Ta-J-		Non Inte Diar	ninal ernal neter	Total 10	l Area 0%	60	%	1 V 53	Vire %
	Trade Size	mm	in.	mm ²	in. ²	mm ²	in. ²	mm^2	in. ²	
12	3∕8				_				_	
16	1/2	15.3	0.602	184	0.285	110	0.171	97	0.151	
21	3⁄4	20.4	0.804	327	0.508	196	0.305	173	0.269	
27	1	26.1	1.029	535	0.832	321	0.499	284	0.441	
35	11/4	34.5	1.360	935	1.453	561	0.872	495	0.770	
41	11/2	40.4	1.590	1282	1.986	769	1.191	679	1.052	
53	2	52.0	2.047	2124	3.291	1274	1.975	1126	1.744	
63	21/2	62.1	2.445	3029	4.695	1817	2.817	1605	2.488	
78	3	77.3	3.042	4693	7.268	2816	4.361	2487	3.852	
91	31/2	89.4	3.521	6277	9.737	3766	5.842	3327	5.161	
103	4	101.5	3.998	8091	12.554	4855	7.532	4288	6.654	
129	5	127.4	5.016	12748	19.761	7649	11.856	6756	10.473	
155	6	153.2	6.031	18433	28.567	11060	17.140	9770	15.141	

System Design: 480 V Feeder from Transf to MCC

- Per NEC Chapter 9, Table 4:
- For PVC, a conduit diameter of 78 mm has an area of 4693 mm²
- For 15 kV, 100% insulation:
- Fill Factor = 1246.4 mm²/4693 mm² = 26.6%
- FF < 40%, OK

System Design: 480 V Feeder from Transf to MCC

- Per NEC Chapter 9, Table 4:
- For PVC, a conduit diameter of 78 mm has an area of 4693 mm²
- For 15 kV, 133% insulation:
- Fill Factor = 1508.1 mm²/4693 mm² = 32.1%
- FF < 40%, OK



Utility Voltage Supply Affects Reliability

- Most utility distribution circuits are 12 kV, 13.8 kV, etc.
- Obtaining a higher utility voltage circuit will increase reliability
- Don't always have a choice in utility voltage
- If available, a higher transmission voltage like 46 kV, 60 kV, etc. is advantageous

Utility Voltage Supply Affects Reliability

- Higher voltage circuit means more power transfer capability
- Also means fewer direct connections to other customers
- Also means lesser chances for the line to fail or impacted by other customers
- Transmission circuits usually feed distribution substations down to 12 kV



System Optimization – Siting Main Substation

- In siting the utility substation for a plant, system optimization helps to reduce costs
- Most utilities are only obligated to bring service to the nearest property line
- If you want the place the utility substation at the opposite corner, you will have to pay for the extra construction around the plant or thru the plant

Location of Main Substation

- Electric utility circuit is usually MV
- Voltage: 12.47 kV or 13.8 kV, 3-phase
- Capacity: 7-12 MW per circuit for bulk power
- Main substation near existing lines
- Utility obligated to bring service to property line
- Represent large revenue stream of kWh

Reference: Rule 16, Service Extensions, per SCE, LADWP, PG&E, SMUD



Location of Main Substation



Location of Main Substation

- You pay for extension of line around property
- You pay for extension of line within property
- Line losses increase = square of current x resistance, or I²R

CAVEATS

- Pay for losses in longer feeder circuit as in kWh
- May be limited in choices of site plan
- Need to catch layout early in conceptual stages





Electrical Center of Gravity

- Should optimize location of large load center balanced with small loads
- Example is pump station, with 10-100 Hp pumps
- Optimized location would have pump station next to main substation
- Minimize voltage drop and losses in feeder cables

Location of Large Load Centers

- Locate large load centers near main substation
- Example: Pump stations with large Hp motors
- Minimize losses in feeder conductors
- Optimum: electrical "center-of-gravity" of all loads
- Run SKM, ETAP, etc., power systems software to optimize system



Location of Large Load Centers





- Also known as a main-tie-main power system
- The main-tie-main can be both at 12 kV or 480 V to take advantage of two separate power sources
- At 480 V, there are two 12 kV to 480 V transformers feeding two separate 480 V buses with a tie breaker between



- At 12 kV, there are two 12 kV sources with a 12 kV tie breaker between
- The two 12 kV sources should be from different circuits for optimum redundancy
- If not, reliability is reduced, but at least there is a redundant 12 kV power train



- For process optimization, the loads should be equally distributed between the buses
- Example, four 100 Hp pumps
- Should be Pumps 1 and 3 on Bus A, and Pumps 2 and 4 on Bus B
- If all four pumps were on Bus A, and Bus A failed, you have zero pumps available

- Normally, main breaker A and main breaker B is closed and the tie breaker is open
- For full redundancy, both transformers are sized to carry the full load of both buses
- Normally, they are operating at 50% load
- In the previous example, each transformer is sized at 2000 kVA, but operating at 1000 kVA when the tie breaker is open

BUILDING A WORLD OF DIFFERENCE®






Double Ended Substation



BUILDING A WORLD OF DIFFERENCE®



Double Ended Substation



Dual Redundant Transformers, Main-Tie-Main



Dual Redundant Transformers, Main-Tie-Main



Dual Redundant Transformers, Main-Tie-Main





Main-Tie-Tie Main System

- For personnel safety, a dummy tie breaker is added to create a main-tie-tie-main system
- When working on Bus A for maintenance, all loads can be shifted to Bus B for continued operation
- Then the tie breaker is opened and Bus A is dead
- However, the line side of the tie breaker is still energized
- Hence, a dummy tie is inserted to eliminate the presence of voltage to the tie breaker



Main-Tie-Tie Main System





- Recall: I²R losses increase with square of current
- Worst case is large load far away
- Fuzzy math: increase voltage and reduce current
- Example: 1,500 kVA of load, 3-phase
- Current at 480 V = 1500/1.732/.48 = 1804 A
- Current at 4.16 kV = 1500/1.732/4.16 = 208 A
- Current at 12.47 kV = 1500/1.732/12.47 = 69 A

 Sizing feeders: 100% noncontinuous + 125% of continuous

```
Reference: NEC 215.2(A)(1)
```

- Engineering practice is 125% of all loads
- Sometimes a source of over-engineering

- Example: 2-500 Hp pumps + 1-500 Hp standby
- Worst-worst: All 3-500 Hp pumps running
- What if system shuts down or fails
- May need 4th pump as standby

- Recall: I²R losses increase with resistance
- As conductor diameter increases, resistance decreases
- Can increase all conductors by one size to decrease resistance
- Thereby decreasing line losses & increase energy efficiency
- Comes at increased cost for cables/raceway

Reference: Copper Development Association

- 480 V: "drop more Cu in ground" w/600 V cable
- 5 kV cable: more expensive than 600 V cable
- 15 kV cable: more expensive than 5 kV cable
- 4.16 kV switchgear: more expensive than 480 V switchgear or motor control centers
- 12.47 kV swgr: more expensive than 4.16 kV
- Underground ductbank is smaller with MV cables

- Previous example with 1,500 kVA load:
- At 480 V, ampacity = 1804 A x 125% = 2255 A
- Ampacity of 600 V cable, 500 kcmil, Cu = 380 A

Reference: NEC Table 310.16

- Need six per phase: 6 x 380 A = 2280 A
- Feeder: 18-500 kcmil + Gnd in 6 conduits

- At 4.16 kV, ampacity = 208 A x 125% = 260 A
- Ampacity of 5 kV cable, 3/0 AWG, Cu = 270 A
- Reference: NEC Table 310.77, for MV-105, 1 ckt configuration
- Feeder: 3-3/0 AWG, 5 kV cables + Gnd in 1 conduit

- At 12.47 kV, ampacity = 69 A x 125% = 87 A
- Ampacity of 15 kV cable, 6 AWG, Cu = 97 A
- Ampacity of 15 kV cable, 2 AWG, Cu = 165 A

Reference: NEC Table 310.77, for MV-105, 1 ckt configuration

- 2 AWG far more common; sometimes costs less
- Larger conductor has less R, hence less losses
- Feeder: 3-2 AWG, 15 kV cables + G in 1 conduit

- Use of MV-105 is superior to MV-90 cable for same conductor size
- The 105 or 90 refers to rated temperature in C
- MV-90 is being slowly phased out by manufacturers today

• Higher ampacity available from MV-105

Conductor Size	<u>MV-90 Amps</u>	<u>MV-105 Amps</u>	
2 AWG, 5 kV	145 A	155 A	
2/0 AWG, 5 kV	220 A	235 A	
4/0 AWG, 5 kV	290 A	310 A	
500 kcmil, 5 kV	470 A	505 A	

Reference: NEC Table 310.77, 1 circuit configuration

- Multiple circuits in ductbank require derating
- Heat rejection due to I²R is severely limited
- Worst case: middle & lower conduits; trapped

No. of Circuits	Ampacity	
1	270 A	
3	225 A	
6	185 A	

Reference: NEC Table 310.77, for 3/0 AWG, Cu, 5 kV, MV-105

NEC based on Neher-McGrath (ETAP software)

- Two basic types of transformers:
- Liquid-filled transformers (2 types)
 - Pad-Mount type
 - Substation type
- Dry-type transformers



BUILDING A WORLD OF DIFFERENCE®

Liquid-Filled: Pad-Mount Type Transformer





Liquid-Filled: Substation Type Transformer



BUILDING A WORLD OF DIFFERENCE®



Dry-Type Transformer



BUILDING A WORLD OF DIFFERENCE®



Dry-Type Transformer



- Common mistake is to oversize transformers
- Example: Average load is 1,500 kVA, then transformer is 1,500 or even 2,000 kVA
- Prudent engineering: cover worst case demand
- There's a better way and still use solid engineering principles

- Use the temperature rise rating and/or add fans for cooling
- For liquid-filled transformers in 1,500 kVA range:
- Standard rating is 65°C rise above ambient of 30°C
- Alternate rating is 55/65°C, which increases capacity by 12%

Reference: ANSI/IEEE Standard 141 (Red Book), section 10.4.3

- Capacity can be further increased with fans
- OA = liquid-immersed, self-cooled
- FA = forced-air-cooled
- Reference: ANSI/IEEE Standard 141 (Red Book), Table 10-11
- In 1,500 kVA range, adding fans increases capacity by 15%

Reference: Westinghouse Electrical Transmission & Distribution Reference Book



- Example: 1,500/1,932 kVA, OA/FA, 55/65°C
 - OA, $55^{\circ}C =$ 1,500 kVAOA, $65^{\circ}C =$ 1,680 kVA(1.12 x 1,500)FA, $55^{\circ}C =$ 1,725 kVA(1.15 x 1,500)FA, $65^{\circ}C =$ 1,932 kVA(1.15 x 1.12 x 1,500)
- Increased capacity by 29%
- Avoid larger transformer and higher losses
- Note: All we did was cool the transformer

- Same concept for dry-type transformers
- AA = dry-type, ventilated self-cooled
- FA = forced-air-cooled

Reference: ANSI/IEEE Standard 141 (Red Book), Table 10-11

• Adding fans increases capacity by 33.3%

Reference: ANSI Standard C57.12.51, Table 6

• Example: 1,500/2000 kVA, AA/FA

- Transformers are ubiquitous throughout water & wastewater plants
- Transformer losses = 2 components:
- No-load losses + load losses
- No-load = constant when transformer energized
- Load = vary with the loading level

• Losses for 1,500 kVA transformer (W)

Туре	<u>No-Load</u>	<u>Full-Load</u>	Total (W)
Dry-Type	4,700	19,000	23,700
Liquid (sub)	3,000	19,000	22,000
Liquid (pad)	2,880	15,700	18,580

Reference: Square D Power Dry II, Pad-Mount, & Substation Transformers

• Efficiencies for 1,500 kVA transformer at various loading levels (%)

Туре	<u>100%</u>	<u>75%</u>	<u>50%</u>
Dry-Type	98.44	98.65	98.76
Liquid (sub)	98.55	98.80	98.98
Liquid (pad)	98.78	98.97	99.10

Reference: Square D Power Dry II, Pad-Mount, & Substation Transformers

- Trivial difference between 98.44% (dry) and 98.78% (liquid), or 0.34%?
- Assume 10-1500 kVA transformers for 1 year at \$0.14/kWh = \$62,550 savings

 Heat Contribution for 1,500 kVA transformer at various loading levels (Btu/hr)

Туре	<u>100%</u>	<u> 75% </u>	<u> 50% </u>
Dry-Type	80,860	52,510	32,240
Liquid (sub)	75,065	46,700	26,445
Liquid (pad)	N/A	N/A	N/A

Reference: Square D Power Dry II & Substation Transformers

- Energy Policy Act 2005 effective Jan 1, 2007; uses NEMA TP-1 standards as reference
- Mandates transformers meet efficiency levels, especially at low loads > larger share of total
- Target: higher grade of grain oriented steel
- Thinner gauge and purer material quality
- Reduces heat from eddy/stray currents

Reference: New Energy Regulations to Impact the Commercial Transformer Market, Electricity Today, March 2007
- Can you exceed the rating of a transformer?
- Without loss of life expectancy?
- Depends on the following conditions:
- Frequency of overload conditions
- Loading level of transformer prior/during to overload
- Duration of overload conditions

Reference: ANSI/IEEE C57.92, IEEE Guide for Loading Mineral-Oil-Immersed Power Transformers Up to and Including 100 MVA

Allowable overload for *liquid-filled* transformer, 1 overload/day

Duration	<u> </u>	<u>70%</u>	<u>50%</u>
0.5 hrs	1.80xRated	2.00xRated	2.00xRated
1.0 hrs	1.56xRated	1.78xRated	1.88xRated
2.0 hrs	1.38xRated	1.54xRated	1.62xRated
4.0 hrs	1.22xRated	1.33xRated	1.38xRated
8.0 hrs	1.11xRated	1.17xRated	1.20xRated

Reference: Square D Substation Transformers

- Overloading a transformer is not strictly taboo
- Okay if you can engineer the system and control the conditions, i.e., dual redundant transformers
- Allows purchase of smaller transformer
- Less losses, higher energy efficiency, lower energy costs

- Spill containment issues with liquid-filled: PCB, mineral oil, silicone, etc.
- Mitigated by using environmentally benign fluid:
- Envirotemp FR3 is soy-based, fire-resistant, PCBfree, can cook with it
- Meets NEC & NESC standards for less-flammable, UL listed for transformers

Reference: Cooper Power Systems Envirotemp FR3 Fluid

- For a typical transformer: 1,500 kVA, 5/15 kV primary, 480Y/277 V secondary
- Cost is about 45% to 93% higher for dry-type vs. liquid-filled
- Adding fans and temp ratings costs are incremental: capital cost only

Reference: 2000 Means Electrical Cost Data, Section 16270

- Maintenance/Reliability
- Most significant and salient point
- Not advisable to have radial feed to one transformer to feed all loads
- Dual-redundant source to two transformers with main-tie-main configuration for reliability and redundancy; transformers at 50% capacity
- Decision Point: Lower capital cost with radial system vs. high reliability and flexibility

Dual Redundant Transformers, Main-Tie-Main



Dual Redundant Transformers, Main-Tie-Main



Dual Redundant Transformers, Main-Tie-Main





Emergency/Standby Engine-Generators

- Very common source of alternate power on site
- Diesel is most common choice for fuel
- Generator output at 480 V or 12 kV
- NEC Article 700, Emergency Systems, directed at life safety
- Emergency: ready to accept load in 10 seconds maximum

Emergency/Standby Engine-Generators

- NEC Article 701, Legally Required Standby Systems, directed at general power & Itg
- Standby: ready to accept load in 60 seconds maximum
- Both are legally required per federal, state, govt. jurisdiction
- Similar requirements, but more stringent for emergency
- Example: equipment listed for emergency, exercising equipment, markings, separate raceway

Emergency/Standby Engine-Generators

- NEC Article 702, Optional Standby Systems, directed at non-life safety, alternate source
- Even less stringent requirements



- Used in conjunction with emergency/standby power sources
- Constantly sensing presence of normal power source, utility, using UV relay
- When normal power source fails, automatic sends signal to start engine-generator
- When up to speed, transfers from NP to EP, in open transition





BUILDING A WORLD OF DIFFERENCE®





- Open transition: Break-Before-Make, or finite dead time
- Upon return of utility power, initiate time delay
- To ensure utility power is stable and not switching of circuits while restoring system
- After time delay timeout, ATS transfers back to NP, in open transition
- Plant loads will be down momentarily

- Option is Closed transition: Make-Before-Break, no dead time
- For brief time, the engine-generator is operating in parallel with utility
- Plant loads stay up
- In closed transition, then subject to utility regulations for parallel generation

- Need to match voltage, frequency, and phase angle with utility source
- Phase angle is most important, worst case is 180 degrees out of phase
- Other consideration is preventing small generator feeding out of plant into utility distribution network
- Load would be too large for small generator
- Generator can't generate enough power and excitation collapses
- Would trip out on low voltage and/or low frequency



- UPS units are very common sources of backup AC power for a variety of uses
- They can be very large to power 100s of kWs of critical loads in the power system
- Or they can be small on the order of a few kW to power control system functions

- A true UPS is always on line
- Incoming AC is converted to DC thru a bridge rectifier to a DC bus
- The DC bus charges a battery bank
- Power from the DC bus is then inverted to AC for use by loads
- If normal power fails, power to the loads is maintained without interruption
- AC output power is being drawn from the batteries
- Battery bank is no longer being charged

- An off-line unit is technically not a UPS since there is a static switch for transferring between sources
- An off-line unit feeds the load directly from the incoming utility AC power
- A portion of the incoming AC power is rectified to DC and charges a battery bank
- If normal power fails, the static switch transfers to the inverter AC output
- Again, the AC output power is being drawn from the battery bank

- Some off-line units today employ very fast static transfer switches that allege to be so fast the loads won't notice
- Need to research this carefully since some computer loads cannot handle a momentary outage
- However, a reliable power system design would include a true on-line UPS unit so the momentary outage question is no longer relevant



Switchgear Auxiliaries

- Switchgear auxiliaries are an important component in power system reliability
- Applies to both 12 kV switchgear and 480 V switchgear, or whatever is in the power system
- The ability to continue to operate after utility power fails is critical



Switchgear Auxiliaries

- Key Components:
- Control power for tripping
- Charging springs
- Relays
- PLC for automatic functions



Switchgear Control Power for Tripping Breakers

- If there is a fault in the system, the relay must sense the fault condition and send a trip signal to the breaker to clear the fault
- A fault could happen at any time
- Could be minutes after the utility circuit fails
- Must clear the fault

Switchgear Control Power for Tripping Breakers

- The circuit breaker contactor is held closed under normal operations
- When a fault is detected, the trip coil in the breaker control circuit operates the charged spring to quickly open the contactor
- If control power is available, the motor operated spring immediately recharges for the next operation
- Typical demand from the charging motor is about 7 A for about 5-10 seconds



Switchgear Control Power

- Maintaining a secure source of power for control of the switchgear is essential
- If there is a fault in the system, the relay must sense the fault condition and send a trip signal to the breaker to clear the fault
- Several sources of control power:
- Stored energy in a capacitor
- 120 VAC
- 125 VDC or 48 VDC



Switchgear Control: Stored Energy (Capacitors)

- Only useful for non-critical systems
- Amount of stored energy is limited
- Not commonly used

Switchgear Control: 120 VAC

- Only operational while 120 VAC is available
- First option is obviously 120 VAC from the utility
- If utility fails, then could be a small UPS
- Not well liked by maintenance personnel since they have to be continually checking the operability and functionality of small UPS units all over the place
Switchgear Control: 120 VDC or 48 VDC

- Most reliable since control power is obtained directly from the battery bank
- There is no conversion to AC
- Less chance of component failure

Switchgear Relays

- Can be powered from 120 VAC
- For reliability, select 125 VDC, particularly when there is a battery bank for switchgear control
- Relays are a critical component in order to detect the presence of a fault on a circuit
- Again, the fault must be cleared

PLC for Overall Substation Control

- A PLC can be just as critical to switchgear operation if there are other automatic functions carried out by the PLC
- The PLC can also detect alarm signals and send them on to the central control room or dial a phone number for help
- For reliability, select 125 VDC as the power source for the PLC
- Or the same small UPS used for switchgear control power

Elbow Terminations for MV Cable

- Terminations for MV cable can sometimes be a point of failure in the power system
- Most common is the use of stress cones and skirts with bare surfaces exposed
- The concept is to prevent a flashover from the phase voltage to a grounded surface, or ground fault

Elbow Terminations for MV Cable

- Dirt and dust build up along the cable from the termination can create a flashover path, especially with moisture
- The skirts help to break up the voltage field as it tries to bridge the gap to the grounded potential
- A molded elbow has no exposed energized surfaces
- The elbow also contains the electric field within thereby decreasing chances for corona
- The molded elbow costs a little more but provides another level of reliability in the power system



Demand Side Management

- Managing the duty cycle on large continuous loads can keep systems at a minimum
- Example: Clean-in-Place heater, 400 kW, 480 V 400 kW x 2 hour warm-up cycle = 800 kWh 200 kW x 4 hour warm-up cycle = 800 kWh Lower energy cost in dollars if off-peak
- Program CIP via SCADA CIP to start before maintenance crews arrive via PLC or SCADA
- 400 kW would have increased system size



Questions?

Keene Matsuda, P.E. Black & Veatch (949) 788-4291 ke.matsuda @ieee.org